

**AWI Technical Committee Interpretations,
Architectural Woodwork Standards, Edition 2, 2014**

Architectural Woodwork Standards, Edition 2, 2014; p. 311; Item 10.4.7.2.6 is determined to be a confusing expression of the tolerance. For the purposes of analysis of test data, the following expression shall be used: “If the gap width is greater than 0.38mm in width and greater than 152mm in length respectively, then the gap is non-compliant.”

Architectural Woodwork Standards, Edition 2, 2014; p. 311; Item 10.4.7.4 is determined to be confusing. The following expression shall be used: “Fabricator shall provide full detail drawings with fastener type/location and pictures of testing, showing methods of joinery and manufacturing. These documents shall be kept in digital form in licensee’s folder, and:”

Architectural Woodwork Standards, Edition 2, 2014; p. 321; Item 10.4.7.16.9.5 is determined to be inadequate. The following expression shall be used: “Metal shelf standards shall extend vertically to within 6” of the top or bottom of the cabinet shelf space, and:”

Architectural Woodwork Standards, Edition 2, 2014; p. 316; Item 10.4.7.10.5.2 is determined that the item results in a conflict in the requirements for visible and concealed surfaces. Therefore, edgebanding may be applied or omitted at the option of the manufacturer.

Architectural Woodwork Standards, Edition 2, 2014; p.303; Items 10.4.4.8.8 and 10.4.4.8.8.1 are deemed to be ambiguous and in conflict with the referenced ANSI/BHMA standard regarding grade requirements, hence conformance cannot be determined.